



Property Line

Install DC Lines in Metallic Conduit on Roof. Use Watertight Fittings and Paint to Match Existing

Existing Roof 4:12 or 18.4° From Horiz. Mat'l Comp. Shingle, Gray/Grn Typ All Locs

Photovoltaic Array Areas 1, 2, 3  
(50) Sharp ND-N2ECU, (2) Sharp ND-72ELU, (2) Sharp ND-72ERU  
Mount All Modules Flat and Parallel to Existing Roof  
Total Area 670 sq ft  
Total Weight 1,890 lbs  
2.8 lbs/sq ft  
See p. 2, 3, 4

Provide Labels at Equipment:  
- System Voltage and Current (NEC 690.53)  
- Safety Warning Labels on all Disconnects  
- Multiple Sources of Power Warning

Existing Service Entrance Panel and PG&E Meter

Mount Inverters and Disconnects on Exterior North Wall

↑  
West Portola Ave.  
↓

← Santa Rita Ave. →

Scale: None



2444 Old Middlefield Way, Suite F  
Mt. View, CA 94043  
Tel 650-938-9574  
Fax 650-938-9573  
www.cobaltpower.com

Project		Robert Lyon Photovoltaic System	
Address		816 Santa Rita Ave. Los Altos, CA 94022	
Date	Feb 25, 2007	Site Plan	Rev 1
Sheet	1 of 4		Signed

